


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Franklin	Fraction S. 1/4 43. S. 1/4 S. E. 1/4	Section number 36	Township number T 17	Range number S R 17 E/W
2. Distance and direction from nearest town or city: 3 1/2 Mile North Street address of well location if in city: Williamsburg				3. Owner of well: Kenneth Edgecomb R.R. or street: R. R. 2 City, state, zip code: Pomona, Kansas 66076		
4. Locate with "X" in section below: 				6. Bore hole dia. 6 in. Completion date 8-6-76 Well depth 195 ft. 21 to 201		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material VC Height: Above ground 21 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 21 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 195 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 290		
				10. Screen: Manufacturer's name Crown Line Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze 1/16 Length 30 Set between 165 ft. and 195 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input type="checkbox"/> No Size range of material: <input type="checkbox"/>		
				11. Static water level: 110 ft. below land surface Date 8-6-76 mg./day/yr.		
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 12 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 21 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
				16. Nearest source of possible contamination: ft. 110 Direction East Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Red Jacket Model number 120-1200 HP 3/4 Volts 220 Length of drop pipe 185 ft. capacity 10 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		This well is a new site. There no contamination at this time. Cement slab will be poured soon.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Signed Elmer Swank Date 8-12-76 Business name Swank Drilling License No. 1044 Address R.R. 1 Ottawa, Kansas Authorized representative		