

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County OSAGE Fraction NW 1/4 SW 1/4 Section number 33 Township number T 17 S R 17 Range number E/W	
2. Distance and direction from nearest town or city: 3 1/2 S of QUENEMO AND 3/4 WEST ON SOUTH SIDE OF ROAD	
3. Owner of well: R.R. or street: City, state, zip code:	
4. Locate with "X" in section below: Sketch map: BARN 	
5. Type and color of material	
	From To
SOIL & CLAY	5 0 5
YELLOW SHELLY	5 5 10
WHITE LIME	13 10 23
(TRACE) BLACK SHALE OR COAL	1 23 24
BLUE LIME	2 24 26
GRAY SHALE	4 26 30
WHITE SAND (WATER 40')	30 30 60
WHITE LIME	2 60 62
GRAY SHALE	11 62 73
BLUE LIME	2 73 75
WHITE SAND	10 75 85
GRAY SHALE	5 85 90
WHITE SAND	25 90 115
GRAY SHALE	3 115 118
WHITE SAND	42 118 160
(Use a second sheet if needed)	
18. Elevation:	19. Remarks: OLD DUG WELL BY HOUSE TO BE FILL AS WALL IS BAD 4X6 WELL CURB AND PUMP HOUSE IN PLACE.
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. SWANK WATERWELL DRILLING Business name: PRT PRINCETON, KS. 66707 Address: George H Swank Date: 6/6/78 Signed: George H Swank Authorized representative	

6. Bore hole dia. 6 1/4 in. Completion date 5/25/78 Well depth 160 ft.
7. <input checked="" type="checkbox"/> Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary
8. Use: <input checked="" type="checkbox"/> Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other
9. Casing: Material PVC Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC <input checked="" type="checkbox"/> Weight ___ lbs./ft. Dia 5 in. to 160 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. SCH 40
10. Screen: Manufacturer's name CROWN LINE Type PVC Dia. 5" Slot/gauze 1/4 HOLES Length 80" Set between 80' ft. and 160" ft. ___ ft. and ___ ft. Gravel pack? No Size range of material ___
11. Static water level: ___ no./day/yr. 40 ft. below land surface Date 6/25/78
12. Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. 124 ft. after 3 hrs. pumping 12 g.p.m. Estimated maximum yield 15 to 20 g.p.m.
13. Water sample submitted: ___ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date ___
14. Well head completion: No Pitless adapter 12 Inches above grade
15. Well grouted? YES With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 50 ft. to SURFACE
16. Nearest source of possible contamination: Talfer Creek ft. 150 Direction EAST Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No
17. Pump: ___ Not installed Manufacturer's name ___ Model number 14 BC HP 1 Volts 230 Length of drop pipe 155 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other