


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Franklin	Township name Greenwood	Fraction SE 1/4	Section number 7	Town number T17S	Range number R18E
Distance and direction from nearest town or city: 1 mi South of Parnoy		3 Owner of well: Kansas Geological Survey		Address: Lawrence, KS.			
Locate with "X" in section below: 		Sketch map:		4 Well depth: 41' ft. Date of completion 10/31/83 Well diameter 5 in.			
2		Type and color of material		From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		brown silty clay		0	20	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Test well	
		brown silty clay with lenses of		20	41	7 Casing: Material PVC Height: above below 15' Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <input type="checkbox"/> in. Diam. 5 in. to 41' ft. depth Weight <input type="checkbox"/> lbs./ft. <input checked="" type="checkbox"/> No in. to <input type="checkbox"/> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
		chert gravel				8 Screen: Manufacturer Type Hand slotted Dia. 5" PVC Slot/gauze 5' Length 5' Set between <input type="checkbox"/> ft. and 36' ft. 41' Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 40-1	
						9 Static water level: 15 ft. below land surface Date 10-26-83	
						10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 37 ft.	
						14 Nearest source of possible contamination: upland ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						15 Pump: NONE <input type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KGS Business name KGS License No. ____ Address Lawrence, KS Signed [Signature] Date 10/31/83 Authorized representative	