

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: <u>Franklin</u>		Fraction: <u>3/4 3/4 1/4</u>	Section number: <u>EX 11</u>	Township number: <u>EX 17 S</u>	Range number: <u>R 18 E</u>
2. Distance and direction from nearest town or city: <u>5 1/2 miles west</u> Street address of well location if in city:			3. Owner of well: <u>Rob Brown</u> R.R. or street: <u>None</u> City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: <u>SEPTIC HOUSE ROAD</u>		
5. Type and color of material			From	To	6. Bore hole dia. _____ in. Completion date: <u>5-27-79</u> Well depth: <u>100</u> ft.
<u>Soil and Clay</u>			<u>0</u>	<u>4</u>	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____
<u>Sand Rock</u>			<u>4</u>	<u>12</u>	8. Use: <u>2</u> Domestic _____ Public supply _____ Industry _____ Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____
<u>Grey Shale ROCK</u>			<u>12</u>	<u>17</u>	9. Casing: Material _____ Height: Above <u>2 1/2</u> ft. 2 1/2 Threaded _____ Welded _____ Surface <u>10</u> in. RMP _____ PVC _____ A _____ Weight <u>3 1/2</u> lbs./ft. Dia. <u>6</u> in. to <u>2 1/2</u> ft. depth; Wall thickness, inches _____ Dia. _____ in. to _____ ft. depth; gage No. <u>Sen. 40</u>
<u>lime rock</u>			<u>17</u>	<u>19</u>	10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauge _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? _____ Size range of material _____
<u>lime shale</u>			<u>19</u>	<u>25</u>	11. Static water level: <u>27</u> ft. below land surface Date: <u>5-27-79</u>
<u>lime shale</u>			<u>25</u>	<u>37</u>	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>18</u> _____ g.p.m.
<u>lime shale</u>			<u>37</u>	<u>50</u>	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
<u>Gray Sand</u>			<u>50</u>	<u>32</u>	14. Well head completion: _____ Pitless adapter _____ <u>3 1/2</u> inches above grade
<u>Yellow Sand Rock</u>			<u>70</u>	<u>80</u>	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>4</u> ft. to <u>20</u> ft.
<u>Sandy Yellow Shale</u>			<u>70</u>	<u>80</u>	16. Nearest source of possible contamination: ft. _____ Direction <u>SE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
<u>Gray Sand</u>			<u>80</u>	<u>85</u>	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____
<u>White Sand</u>			<u>85</u>	<u>85</u>	18. Elevation:
<u>Gray Sand</u>			<u>85</u>	<u>100</u>	19. Remarks: <u>This well was cased to solid sand rock. The best of the well was solid walls. No known contamination at time of drilling.</u>
<u>White Sand (water)</u>			<u>100</u>	<u>101</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Edgar Swank Drilling 124</u> Business name _____ License No. _____ Address <u>R.R. 4 Ottawa, Kans.</u> Signed: <u>Edgar Swank</u> Date <u>8-19-79</u> Authorized representative
<u>White Sand (water)</u>			<u>101</u>	<u>101</u>	
(Use a second sheet if needed)					
18. Elevation: Topography: ____ Hill <input checked="" type="checkbox"/> Slope ____ Upland ____ Valley					