


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Franklin	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 25	Township number T 17 S	Range number R 18 E
<input checked="" type="checkbox"/> Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: Keith Manwarren R.R. or street: 1342 S Mulberry City, state, zip code: Ottawa, Kan.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6" Completion date 12-14-78 Well depth 60 ft. 9" to 15		
				7 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
soil		0	15	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight sch 40 lbs./ft. Dia. 5 in. to 60 ft. depth Wall thickness sch 40 inches Dia. 5 in. to 60 ft. depth gage No. sch 40		
muddy gravel		15	40	10. Screen: Manufacturer's name g crown line Type pvc Dia. 5 Slot/gauze 3/8 Length 20 Set between 20 ft. and 40 ft. ft. and 40 ft. Gravel pack? yes Size range of material 1/4		
grey shald		40	60	11. Static water level: 15 ft. below land surface Date 12-14-78		
				12. Pumping level below land surfaces: ft. after 8 hrs. pumping 8 g.p.m. ft. after 8 hrs. pumping 8 g.p.m. Estimated maximum yield 8 g.p.m.		
				<input checked="" type="checkbox"/> Water sample submitted: 12-14-78 mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12-14-78		
				14. Well head completion: pump House Pitless adapter 15 inches above grade		
				15. Well grouted? <input type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
				16. Nearest source of possible contamination: Pasture ft. 17 Direction 180 Type 25-NES-USE Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Royce Swank Model number 371 HP 3 Volts 115 Length of drop pipe 3-9-79 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Royce Swank Drilling 371 Business name RRL Ottawa Kan. 66067 License No. 3-9-79 Address Royce Swank Signed 3-9-79 Date 3-9-79 Authorized representative		