

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Couldnt locate -
Jurnal
June 8,

Legal is wrong

1. Location of well:		County Franklin	Fraction S.W. 1/4 N.E. 1/4 S.W. 1/4	Section number 11	Township number T 17 S	Range number R 19 E
2. Distance and direction from nearest town or city: 5 1/2 Miles West Street address of well location if in city: Ottawa, Kansas			3. Owner of well: Bob Leach R.R. or street: R.R. City, state, zip code: Pomona, Kansas 66076			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: SEPTIC house ROAD			6. Bore hole dia. 6 1/2 in. Completion date 8-6-79 Well depth 144 ft. 9' to 20'			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Soil and Clay			9. Casing: Material <input type="checkbox"/> Height: Above <input type="checkbox"/> 18 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> Sch. 40 RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> 27 1/2 lbs./ft. Dia. 6 in. to 2 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. Sch. 40			
			10. Screen: Manufacturer's name NONE Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input type="checkbox"/> Size range of material <input type="checkbox"/>			
Sand Rock			11. Static water level: 25 ft. below land surface Date 8-6-79			
Gray Shale XXXX			12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 18 g.p.m.			
Lime Rock XXXX			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
Gray Shale XXXX			14. Well head completion: <input type="checkbox"/> Pitless adapter 3' Inches above grade			
Gray Sandy Shale			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 20 ft.			
Gray Sand			16. Nearest source of possible contamination: ft. 100 Direction North Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
White Sand			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Gray Sand			18. Elevation:			
White Sand (Water)			19. Remarks: This Well was cased to solid sand rock. The rest of the well was solid walls. No known contamination at time of drilling.			
Gray Shale			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Edgar Swank Drilling 124 Business name R.R. 4 Ottawa, Kans. Address R.R. 4 Ottawa, Kans. Signed Edgar Swank Date 8-19-79 Authorized representative			
White Sand (Water)			Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			