

Sent to Leonard
6/30/77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY:

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County FRANKLIN	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 20	Township number T 17 S	Range number R 21 E	EW
2. Distance and direction from nearest town or city: 5 N OF			3. Owner of well: CITY OF RANTOUL			
Street address of well location if in city: RANTOUL, KS.			R.R. or street: City, state, zip code: RANTOUL, KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 18 in. Completion date _____ Well depth 42 ft. 6-23-77		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC 91 Weight 4.1 lbs./ft. Dia. 6 in. to 42 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 316		
				10. Screen: Manufacturer's name _____ Pumpco Type PVC Dia. 6 Flow gauge 020 Length 10 Set between 23 ft. and 33 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 0.3 x 0.6		
				11. Static water level: _____ mo./day/yr. 12 ft. below land surface Date 6-23-77		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: CAP <input checked="" type="checkbox"/> Pitless adapter 36 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction W Type DRAINAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: we will install slab		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Oil & Gas Inc 182 Business name License No. _____ Address RT 1 Holtan, KS Signed Dale Bohren Date 6-21-77 Authorized representative		

17 210 20 20 SE SE SE
 T R W Sec 1/4 1/4 1/4