

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MORRIS	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 15	Township number T 17 S R 5 E X	Range number
2. Distance and direction from nearest town or city: 1 1/2 W. 3/4 N. Street address of well location if in city: from Burdick, Ks.			3. Owner of well: Melvin L. Christner R.R. or street: R.R. 1 City, state, zip code: Burdick, Kansas 66838			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 6 in. Completion date 4-2-80 Well depth 116 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Cleaned and Re-lased Existing Well. No Samples Available					9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 15 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 1/2 lbs./ft. Dia. 5 in. to 7 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. SDR 31-200	
					10. Screen: Manufacturer's name Certain Teed Type Plastic Dia. 5 in Slot/gauge 3/32 x 4 Length 40 ft. Set between 7 1/2 ft. and 11 1/2 ft. Gravel pack? No Size range of material	
					11. Static water level: 68 ft. below land surface Date 4-2-80 mo./day/yr.	
					12. Pumping level below land surfaces: 80 ft. after 1/2 hrs. pumping 15 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 40 g.p.m.	
					13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 15 inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 2 1/2 ft. to 14 ft.	
					16. Nearest source of possible contamination: ft. 100 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Not installed Manufacturer's name Red Jacket Model number N.A. HP 1/2 Volts 115 Length of drop pipe 105 ft. capacity 11 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Bore Size 0 to 14 ft. 8 in Well is in Compliance with Regulation		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Benda Drilling 161 Business name Lincolnville, Kans. License No. Address Paul W. Benda Date 4-26-80 Signed Paul W. Benda Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5