

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Lyon	From NE 1/4 SE 1/4 SW 1/4	Section number 1	Township number T 18 S R 10 E	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 4 Blks. North of Bank 2 Blks. East			3. Owner of well: James Hannon R.R. or street: 4 th & Elm City, state, zip code: Americus, Kan. 66835			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 9/12/78 Well depth 36 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil, Soft Black		0	2	9. Casing: Material Pits. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/4 in. RMP 1 1/4 Weight 1.8 lbs./ft. Dia. 5 in. to 36 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 4-250		
Clay, Yellow, Soft V. F.		2	10	10. Screen: Manufacturer's name Sunflower Deep Set Styrene Type 250 Dia. 5" Slot/gauze 1/16 Length 10 Set between 26 ft. and 36 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2		
Clay, Dark Yellow, Hard, Coarse		10	22	11. Static water level: 22 ft. below land surface Date 7/12/78 7/12/78 mo./day/yr.		
Clay, Light Yellow, Soft, V.F.		22	34	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Gravel, Light Brown to Dark Yellow V.H.&C.		34	36	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 85 Direction West Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Gould's Model number 103 HP 1/3 Volts 120 Length of drop pipe 34 ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. C & C Well Drilling 346 Business name License No. Address Box 31 Americus, Kan, 66835 Signed Mark Y. Lape Date 9/25/78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5