

LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <u>Lyon</u>	<u>NW 1/4 SW 1/4 NW 1/4</u>	<u>12</u>	T <u>18</u> S	R <u>10</u> EW

Distance and direction from nearest town or city? across the street south of Americus Street address of well if located within city?

2] WATER WELL OWNER: Jacob Kaufer
 RR#, St. Address, Box #: RR #1
 City, State, ZIP Code: Americus, Ki, 66835
 Board of Agriculture, Division of Water Resources
 Application Number:

3] DEPTH OF COMPLETED WELL: 30 1/2 ft. Bore Hole Diameter: 9 in. to 30 1/2 ft., and ... in. to ... ft.
 Well Water to be used as:
 Domestic Feedlot Oil field water supply Air conditioning Injection well
 Irrigation Industrial Lawn and garden only Dewatering Other (Specify below)
 Well's static water level: 15 ft. below land surface measured on 10 month 5 day 82 year
 Pump Test Data: Well water was ... ft. after ... hours pumping. ... gpm
 Est. Yield: 30 gpm: Well water was ... ft. after ... hours pumping. ... gpm

4] TYPE OF BLANK CASING USED:
 Steel RMP (SR) Wrought iron Concrete tile Casing Joints: Glued Clamped
 PVC ABS Fiberglass Other (specify below) Welded
 Blank casing dia: 5 in. to 16 ft., Dia: ... in. to ... ft., Dia: ... in. to ... ft.
 Casing height above land surface: 18 in., weight: 1.59 lbs./ft. Wall thickness or gauge No. 203

TYPE OF SCREEN OR PERFORATION MATERIAL:
 Steel Stainless steel Fiberglass RMP (SR) Asbestos-cement
 Brass Galvanized steel Concrete tile ABS None used (open hole)
 Screen or Perforation Openings Are:
 Continuous slot Mill slot Gauzed wrapped Saw cut None (open hole)
 Louvered shutter Key punched Wire wrapped Drilled holes
 Torch cut Other (specify) ...
 Screen-Perforation Dia: 5 in. to ... ft., Dia: ... in. to ... ft., Dia: ... in. to ... ft.
 Screen-Perforated Intervals: From 16 ft. to 30 1/2 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 Gravel Pack Intervals: From 15 ft. to 30 1/2 ft., From ... ft. to ... ft., From ... ft. to ... ft.

5] GROUT MATERIAL: Neat cement Cement grout Bentonite Other
 Grouted Intervals: From 3 ft. to 13 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 What is the nearest source of possible contamination:
 Septic tank Cess pool Sewage lagoon Fuel storage Abandoned water well
 Sewer lines Seepage pit Feed yard Fertilizer storage Oil well/Gas well
 Lateral lines Pit privy Livestock pens Watertight sewer lines Other (specify below)
 Direction from well: West How many feet: 80 ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted ... month ... day ... year: Pump Installed? Yes No
 If Yes: Pump Manufacturer's name ... Model No. ... HP ... Volts
 Depth of Pump Intake ... ft. Pumps Capacity rated at ... gal./min.
 Type of pump: Submersible Turbine Jet Centrifugal Reciprocating Other

6] CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on 10 month 5 day 82 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 372
 This Water Well Record was completed on 10 month 21 day 82 year under the business name of Lespagnard Water Well Contrs. by (signature) George Lespagnard

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM		TO		LITHOLOGIC LOG	FROM		TO		LITHOLOGIC LOG
	0	3	3	15		15	26	26	31	
	0	3	3	15	top soil					
	3	15	15	26	Tan clay					
	15	26	26	31	Silty clay					
	26	31	31		Gravel					

ELEVATION: Depth(s) Groundwater Encountered 1. 2.6 ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.