

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County POTTAWATOMIE	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 15	Township number T 8	Range number S R 12 E/W
2. Distance and direction from nearest town or city: 3.5 N 3.5 N			3. Owner of well: ROY SMITH			
Street address of well location if in city: OF EMMETT			R.R. or street: City, state, zip code: EMMETT			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 10 in. Completion date 1-19-77 Well depth 80 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2.74		
TOP SOIL		0	4	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot/gauge 1020 Length 60 Set between 20 ft. and 80 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 0.3-1080		
BROWN CLAY (SILTY)		4	27	11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 1-19-77		
GRAVEL		27	30	12. Pumping level below land surfaces: AIR TEST <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1.5 g.p.m.		
SHALEY LIMESTONE (BLK-GRAY)		30	80	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction N Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		OWNER WILL INSTALL SLAB		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Dalg Co Inc 182 Business name License No. Address RT1 HAITON, KS Signed Dale Parker Date 1-19-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

8-12-77
 W
 1-5
 Sec
 1/4
 1/4
 1/4
 NE 1/4 SW