

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

To BWS
4-10-80

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Osage</u> Fraction <u>SW 1/4 SE 1/4 NE 1/4</u> Section number <u>2</u> Township number <u>T 18 S R 16 E 11</u> Range number <u>16</u>	
2. Distance and direction from nearest town or city: <u>1/2 mi N 3/4 E</u> 3. Owner of well: <u>City of Melevorn</u> Street address of well location if in city: <u>Emeleover</u> R.R. or street: City, state, zip code:	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> </div>	
5. Type and color of material	
	From To
soil	0 10
river mud	10 29
shald	29 41
lime	41 46
grey sand shalde	46 50
white sand	50 90
blue shald	90 120
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
6. Bore hole dia. <u>8 1/2</u> in. Completion date <u>4/15/79</u> Well depth <u>120</u> ft. <u>12" to 41'</u>	
7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36"</u> in. RMP <u>steel</u> PVC <input checked="" type="checkbox"/> Weight <u>sch 40</u> lbs./ft. Dia. <u>6 1/2</u> in. to <u>42</u> ft. depth Wall Thickness: inches or Dia. <u>6 1/2</u> PVC <u>120</u> ft. depth Gage No. <u>sch 40</u>	
10. Screen: Manufacturer's name <u>crown line</u> Type <u>PVC</u> Dia. <u>6 1/2</u> Slot/gauze <u>3/8</u> Length <u>40</u> Set between <u>50</u> ft. and <u>90</u> ft. Gravel pack? <u>no</u> Size range of material	
11. Static water level: <u>46</u> ft. below land surface Date <u>8/2/79</u> mo./day/yr.	
12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield: <u>21</u> g.p.m.	
13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>42</u> ft.	
16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Royce Swank Drilling 371</u> Business name License No. _____ Address <u>RR1, Ottawa, Kan 66067</u> Signed <u>Royce Swank</u> Date <u>3/20/80</u> Authorized representative	

T 18 S R 16 E 11
 SW SE NE
 1/4 1/4 1/4
 30