

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Osage	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 9	Township number T 18 S R 16 E/W	Range number
2. Distance and direction from nearest town or city: 1 Mi. South			3. Owner of well: Howard Masterson		
Street address of well location if in city: Melvern			R.R. or street: RR1		
			City, state, zip code: Melvern, Kan. 66510		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 1/4 in. Completion date 5-3-79	
N 1 Mile W E S 1 Mile		Sketch map showing well location with 'X' in SE 1/4 section, labeled 'X well', 'Septic', and 'H. 31'.		Well depth 140 ft. 9" to 20	
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight sch 40 lbs./ft. Dia. 5 1/2 in. to 140 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. sch 40	
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____ Crown Line	
soil		0	1	Type PVC Dia. 5 1/2	
shelly Rock		1	5	Slot/gauze 3/8 Length 20	
clay		5	7	Set between 120 ft. and 140 ft.	
lime		7	30	Gravel pack? <input checked="" type="checkbox"/> no Size range of material _____	
black shald		30	35	11. Static water level: _____ 50 ft. below land surface Date 5-3-79	
lime		35	38	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.	
shald		38	55	13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____	
lime		55	85	14. Well head completion: Pump HOUSE _____ Pitless adapter _____ Inches above grade	
shald		85	125	15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 20 ft.	
sand		125	140	16. Nearest source of possible contamination: ft. 150 Direction east Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____	
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Royce Swank Drilling 371 Business name License No. Address RR1 Ottawa, Kansas 66067 Signed Royce Swank Date 5-20-79 Authorized representative			

T 18 S R 16 E/W
Sec 9
SESESE
1/4 1/4 1/4