

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Osage		Fraction SW 1/4 SW 1/4 SW 1/4		Section number 10		Township number T 18 S		Range number R 16 E/W	
2. Distance and direction from nearest town or city: 1.5				3. Owner of well R.D. Patterson					
Street address of well location if in city: Melvern				R.R. or street: City, state, zip code: Melvern, Kans., 66510					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 1/2 in. Completion date 11-22-78 Well depth 100 ft. 9" to 20					
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
				9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight sch 40 lbs./ft. Dia. 6 1/2 in. to 20 ft. depth Wall Thickness _____ inches or Dia. 5 in. to 100 ft. depth Gage No. sch 40					
				10. Screen: Manufacturer's name _____ crow line Type PVC Dia 5 Slot/gauze 3/8 Length 20 Set between 80 ft. and 100 ft. _____ ft. and _____ ft. Gravel pack <input checked="" type="checkbox"/> Size range of material _____					
				11. Static water level: 50 ft. below land surface Date 11-22-78 11 mo./day/yr.					
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1 1/2 g.p.m.					
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
				14. Well head completion: Pump house <input type="checkbox"/> Pitless adapter _____ inches above grade					
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.					
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No					
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Royce Swank Drilling 371 Business name _____ License No. _____ Address RR1 Ottawa, Kan Signed Royce Swank Date 11-22-78 Authorized representative					
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Drill in a middle of a pasture.							

T 18 S R 16 E W 1/4 SW 1/4 SW 1/4