

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County: <u>Marion</u>	Fraction: <u>NW 1/4 SW 1/4 NE 1/4</u>	Section number: <u>10</u>	Township number: T <u>18</u> S R <u>4</u> E <u>A</u>	Range number: <u>4</u>
2. Distance and direction from nearest town or city: <u>1/2 mi W, 1/2 mi N, from Lincolnville, Kans.</u>		3. Owner of well: <u>Gary Diepenbrock</u> R.R. or street: <u>#1</u> City, state, zip code: <u>Lincolnville, Kans. 66858</u>			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: House Well X Slope Solid Lime Septic Livestock Corrals Barn Shop		
5. Type and color of material			From	To	6. Bore hole dia. <u>10</u> in. Completion date _____ Well depth <u>135</u> ft. <u>1-21-80</u>
Top Soil Black			0	1	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay Brown			1	4	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Limestone			4	10	9. Casing: Material <u>Plastic</u> Height: Above or _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>16</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight <u>5</u> lbs./ft. Dia. <u>8</u> in. to <u>85</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>332</u>
Clay Med. Yellow			10	31	10. Screen: Manufacturer's name _____ <u>Certain Teed</u> Type <u>Plastic</u> Dia. <u>8 in</u> Slot/gauge <u>3/32 x 4 in</u> Length <u>50 ft.</u> Set between <u>85</u> ft. and <u>135</u> ft. _____ ft. and _____ ft. Gravel pack? <u>NO</u> Size range of material _____
Clay Red			31	34	11. Static water level: _____ mo./day/yr. <u>55</u> ft. below land surface Date <u>1-21-80</u>
Lime Hard Gray White			34	64	12. Pumping level below land surfaces: <u>56</u> ft. after <u>2</u> hrs. pumping <u>60</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>100 +</u> g.p.m.
Sand Fine Med. Gray			64	67	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Shale Light Blue			67	92	14. Well head completion: <u>1 Pipe Well Seal</u> <input type="checkbox"/> Pitless adapter <u>16</u> inches above grade
Clay Red			92	98	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.
Lime and Sand Med. Light Gray			98	114	16. Nearest source of possible contamination: <u>Septic</u> ft. <u>165</u> Direction <u>SW</u> Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Hard Flint Rock Gray White			114	118	17. Pump: <u>Dempster</u> Not installed Manufacturer's name <u>Dempster</u> Model number <u>MBC 3300 S2</u> HP <u>3</u> Volts <u>230</u> Length of drop pipe <u>125</u> ft. capacity <u>65</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Sand Coarse Gray White			118	125	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Benda Drilling</u> <u>161</u> Business name License No. Address <u>Lincolnville, Kans 66858</u> Signed <u>Paul J. Benda</u> Date <u>2-6-80</u> Authorized representative
Shale Med Blue			125	135	
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>Bore Size 0 to 15 ft - 12 in</u> <u>A concrete block, pump house, with concrete floor, houses the pumping equipment.</u>				

T 18 R 4 E W 10 Sec NW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5