

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Marion	Fraction SW 1/4 NE 1/4 NW 1/4	Section number 14	Township number T 18 S R 4 E 1	Range number 4
2. Distance and direction from nearest town or city:		In Lincolnvill, Ks.		Owner of well: Robert Kleinschmidt		
Street address of well location if in city:		3rd. & Adams		R.R. or street: Box 221 City, state, zip code: Lincolnvill, Ks. 66858		
4. Locate with "X" in section below:		Sketch map: 			6. Bore hole dia. 7 1/2 in. Completion date 9-15-75 Well depth 101 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Good Top Soil		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown to yellow Clay		2	14	9. Casing: Material Flascol Height: Above or Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 6 in. to 61 ft. depth Wall Thickness 3 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 32 m		
yellow-Rocky formation		14	21	10. Screen: Manufacturer's name Certain Tech Type <input type="checkbox"/> Dia. 6 in Slot/gauze <input type="checkbox"/> Length 40 ft. Set between 61 ft. and 101 ft. ft. and <input type="checkbox"/> ft.		
yellow Clay		21	40	Gravel pack? No Size range of material <input type="checkbox"/>		
Red Clay		40	45	11. Static water level: <input type="checkbox"/> mo./day/yr. 37 ft. below land surface Date 9-15-75		
Blue Shale		45	61	12. Pumping level below land surfaces: No Pump <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping Installed <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 <input checked="" type="checkbox"/> g.p.m.		
Light Gray Sand		61	70	13. Water sample submitted: By Sand in Basket <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Blue Shale		70	92	14. Well head completion: Sealed with Cap <input type="checkbox"/> Pitless adapter 28 inches above grade		
Coarse White + Gray Sand		92	101	15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
Screen is made from solid Plastic Casing by boring 3/8 in dia holes neatly in order at average of 18 holes per ft.				16. Nearest source of possible contamination: Sealed Sewer Line ft. 20ft Direction SE Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	Owner knows of concrete slab to be poured below pitless adapter		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Benda Drilling 161 Business name License No. <input type="checkbox"/> Address Lincolnvill, Ks. Signed Paul W. Benda Date <input type="checkbox"/> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5