

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Marion Fraction SW 1/4 SE 1/4 SW 1/4 Section number 15 Township number T 18 S R 4 E/A Range number	
2. Distance and direction from nearest town or city: 1 mi S, 1 mi W, from Lincolnville, Kans 66858 Street address of well location if in city:	
3. Owner of well: Anton Sika R.R. or street: RR #1 City, state, zip code: Lincolnville, Kans. 66858	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. 6 in. Completion date 11-17-79 Well depth 128 ft.	
7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material Plastic Height: Above or below Threading: <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP: <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 1/2 lbs./ft. Dia. 5 in. to 88 ft. depth Wall Thickness: inches or Dia. in. to ft. depth Gauge No. 258	
5. Type and color of material	
	From To
Top Soil Black	0 2
Clay Brown	2 6
Lime Gray White Clay Dark yellow	6 28
Lime Gray White	28 51
yellow Clay + Lime Gravel-limited water	51 61
Clay Red	61 67
Shale Dark Blue	67 107
Rock Very Hard Flint	107 112
Shale Med Blue with Sandstone-Gray	112 128
10. Screen: Manufacturer's name Certain Feed Type Plastic Dia. 5 in Slot/gauge 3/8 Length 40 ft. Set between 388 ft. and 128 ft. Gravel pack? No Size range of material _____	
11. Static water level: 56 ft. below land surface Date 11-17-79 mo./day/yr.	
12. Pumping level below land surfaces: 115 ft. after 1/2 hrs. pumping 10 g.p.m. Estimated maximum yield 15 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ ma./day/yr.	
14. Well head completion: Well Seal <input checked="" type="checkbox"/> Pitless adapter 14 Inches above grade	
15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 2 1/2 ft. to 14 ft.	
16. Nearest source of possible contamination: ft. 64 Direction N.W. Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: Not installed Manufacturer's name Red Jacket Model number 50W0986 HP 1/2 Volts 110 Length of drop pipe 121 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: This well has a limited supply of water. Bore hole size Top 15ft 8in for Grout
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Benda Drilling 161 Business name License No. Address Lincolnville Kans 66858 Signed Paul W. Benda Date 12-3-79 Authorized representative	

T 18 S R 4 E/A Sec 15 SW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5