

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Chase	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 4	Township number T 18 S	Range number R 9 E
2. Distance and direction from nearest town or city: Street address of well location if in city: Lake Kahola, Kans.				3. Owner of well: R.R. or street: Karl E. Berns City, state, zip code: Lake Kahola, Kans		
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> </div> <div> <p>Sketch map: Lake Kahola</p> </div> </div>				6. Bore hole dia. 8 in. Completion date 10-16-75 Well depth 40 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material plts Height: Above grade XXX Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 15 lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. 5 in. to 40 ft. depth gage No. 32		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Jet Stream Plastics Inc.
Top soil				0	1	Type Styrene Dia. 5 in.
clay				1	3	Slot size .06 Length 10 ft.
limestone				3	4	Set between 25 ft. and 35 ft.
shale, lt. grey				4	5	Gravel pack? yes Size range of material 1/8
limestone, shaley				5	10	11. Static water level: 20 ft. below land surface Date 10-15-75
shale, blue				10	15	12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 70 g.p.m.
limestone				15	17	10 ft. after 1 hrs. pumping 90 g.p.m.
shale, grey				17	22	Estimated maximum yield 90 - 100 g.p.m.
limestone				22	23	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date
shale, blue				23	27	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 inches above grade
limestone -- water bearing				27	31	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete
shale, grey				31	35	Depth: From 0 ft. to 24 ft.
limestone				35	36	16. Nearest source of possible contamination: ft. 150 Direction East Type toilet
shale, grey				36	40	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed
						Manufacturer's name
						Model number 415 HP 1/2 Volts 115
						Length of drop pipe 15 ft. capacity 10 g.p.m.
						Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
19. Remarks: Owner to put building around well to house water system at later date. Owner informed of slab regulation.				Bledsoe Service Co. 153 Business name License No. Address 415 Plum. Cottonwood Falls Signed Paul Bledsoe Date 7-19-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3