

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Chase Fraction NE 1/4 SW 1/4 NE 1/4 Section number 5 Township number T 18 S R 9 E/W Range number	
2. Distance and direction from nearest town or city: 4 mi. SW of Dunlap (Lake Kahola) 3. Owner of well: A. R. Erickson R.R. or street: 625 Walnut City, state, zip code: Emporia, KS, 66801	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
6. Bore hole dia. 6 in. Completion date 9-1-79 Well depth 30 ft.	
7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material Pl. Height: Above or below 18 in. Threading: GL Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.5 lbs./ft. Dia. 5 in. to 30 ft. depth Wall Thickness: inches or Dia. 200 gage No.	
10. Screen: Manufacturer's name Cet Mac Type RMP Dia. 5" Slot/gauze .06 Length 10' Set between 20 ft. and 30 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 14-20	
11. Static water level: 11 ft. below land surface Date 8-31-79 mo./day/yr.	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
14. Well head completion: 18 Pitless adapter _____ Inches above grade	
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentanite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.	
16. Nearest source of possible contamination: 52 ft. Direction SW Type pit privy Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: _____ Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Picked up water between 23 & 26. Owner will prepare slab at top and install pump.
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 372 Lespagnard W.W. Contrs. Business name License No. Address 1312 Trail Ridge Rd, Emporia Sign: George J. Lespagnard Date 9-1-79 Authorized Representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 18 S R 9 E/W Sec 5 NE 1/4 SW 1/4