

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Lyon	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 9	Township number T 19 S R 11 EW	Range number		
2. Distance and direction from nearest town or city: Street address of well location if in city: 2033 W. 7				3. Owner of well: Humberto Felipe R.R. or street: 2037 W. 7 City, state, zip code: Emporia, Ks. 66801				
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: well is c. 10ft. from house		6. Bore hole dia. 6" in. Completion date 6-27-79 Well depth 33 ft.		
5. Type and color of material				From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				Brown clay		0	15	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
				Tan clay		15	28	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded 9/16 Surface <input type="checkbox"/> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 33 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 1200
				Sandy silt		28	30	10. Screen: Manufacturer's name Vess + Lowell Type RMP Dia. 5" Slot/gauze .06 Length 5' Set between 28 ft. and 33 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4-1/2
				Sand and gravel		30	33	11. Static water level: <input type="checkbox"/> mo./day/yr. 13 ft. below land surface Date 6-27-79
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.				
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>				
				14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade				
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
				16. Nearest source of possible contamination: ft. 40' Direction East Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
18. Elevation:		19. Remarks: Concrete slab + well house to be installed by owner (also submersible pump)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 372 Laspaquard M.W. Contrs. Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address 1312 Trail Ridge Rd, Emporia, Mo. Signed Maguel Laspaquard Date 6-28-79 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5