

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Lyon	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 9	Township number T 19 S R 11 E W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 2018 W. 7				3. Owner of well: Leroy Selby R.R. or street: 2018 W. 7 City, state, zip code: Emporia, KS. 66801		
4. Locate with "X" in section below:				Sketch map:		6. Bore hole dia. 6 1/2 in. Completion date Well depth 45 ft. 7-7-79
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay mixed with gravel				0	4	9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded GL Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 6.5 lbs./ft. Dia. 5 in. to 43 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 2.00
Brown clay				4	15	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5" Slot/gauze 1/16" Length 76' Set between 27 ft. and 43 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2
Gravel				15	18	11. Static water level: <input type="checkbox"/> mo./day/yr. 12 ft. below land surface Date 7-10-79
Tan silt (progressively getting more sandy)				18	28	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.
Tan sand (with water; had to be cased out to drill)				28	32	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
Tan sand with gravel				32	43	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 inches above grade
Gray shale				43	45	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.
						16. Nearest source of possible contamination: ft. 30' Direction WEST Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 372 Business name Lespagnard W.W. Contrs License No. Address 1312 Trail Ridge Rd Emporia Signed Genet Lespagnard Date 7-10-79 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		I put 2 ft. of 1" gravel in bottom of hole to allow entrance of water from bottom as well as through perforations. Hit water at 28 ft.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5