

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County LY04	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 11	Township number T 19 S R 11 EW	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 1212 E. 9th			3. Owner of well: Lawrence Palmer R.R. or street: 1212 E. 9th City, state, zip code: Emporia, KS, 66501			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 8-18-80 Well depth 62 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	2	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
Brown clay		2	22	10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? _____ Size range of material _____		
Limestone (very hard)		22	24	11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date _____		
Shale (gray)		24	29	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Limestone (very hard)		29	31	13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
Shale (gray)		31	44	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Limestone		44	46	15. Well grouted? _____ With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.		
Shale (gray)		46	52	16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes _____ No		
Limestone		52	56	17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale (gray)		56	62	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Lespagnard W. W. Contr. 312 Business name _____ License No. _____ Address 1312 Trail Ridge Rd E Signed George J. Lespagnard Date 8-24-80 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: flat <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		About 1/3 gal/min. was coming in at 29 ft. Not enough to irrigate lawn & garden. Hole filled with natural material.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5