

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Lyon	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 24	Township number T 19 S R 11 EW	Range number
2. Distance and direction from nearest town or city: South of Emporia Street address of well location if in city:			3. Owner of well: ROY L STANTON R.R. or street: RT 4 City, state, zip code: Emporia Kan			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 11 in. Completion date 5-8-76 Well depth 48 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil - Blk		0	6	9. Casing: Material PVL Height: (Above) or below Threaded <input type="checkbox"/> Welded glu Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 32 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1200		
Clay - Yellow		6	8	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot/gauze YB Length 16 ft Set between 32 ft. and 48 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4 - 1/2		
Clay - Red		8	26	11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 5-8-76		
Clay - Sandy - Lite Red		26	32	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
Gravel -		32	36 1/2	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Shale - Lite Gray		36 1/2	38	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade		
Shale - Blu		38	44	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Flint - Brn		44	48	16. Nearest source of possible contamination: ft. 100 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks: Re-enforced concrete slab 4'x4'x4" to be installed by customer & Mrs. Roy L. Stanton Sr.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zinn Water Well Drilling 210 Business name _____ License No. _____ Address East Springs, Kan Signed Joseph A. Zinn Date 5-9-76 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5