

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Lyon		Fraction NW 1/4 SE 1/4 S&E 1/4		Section number 30		Township number T 19 S		Range number R 12 EAW	
2. Distance and direction from nearest town or city: 2 E - 23 3/4				3. Owner of well: Ron Brammell					
Street address of well location if in city: Emporia				R.R. or street: 2301 Luther					
				City, state, zip code: Emporia, Ks. 66801					
4. Locate with "X" in section below:		Sketch map:				6. Bore hole dia. 5 in. Completion date 3-21-77 Well depth 32 ft.			
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Top Soil		0		2		9. Casing: Material PCW Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC blue Weight 2.74 lbs./ft. Dia. 5 in. to 32 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258			
Brown Silt		2		13		10. Screen: Manufacturer's name Pumpeo M.P.E. Type PVC Dia. 5 Slot/gauze 020 Length 10' Set between 22 ft. and 32 ft. ft. and <input type="checkbox"/> ft.			
Brown Clay		13		28		Gravel pack? <input checked="" type="checkbox"/> Size range of material 020-080			
Gray Clay		23		25		11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 3-21-77			
Gray Fine Sand		25		26		12. Pumping level below land surfaces: Air Test <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.			
Gray Fine Sand to med Gravel		26		32		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
						14. Well head completion: Top cap <input type="checkbox"/> Pitless adapter 24 Inches above grade			
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
						16. Nearest source of possible contamination: ft. 100 Direction N Type River Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
						(Use a second sheet if needed)			
18. Elevation:		19. Remarks:				20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		Owner to pour slab Dwight, This is one of Ebbort wells THAT WAS SUB-CONTRACTED. SUPER CHLORINATED 8-31-77 - 5009A. H2O + 32oz. 70% H.T.H. pumped into well @ 60 G.P.M.				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Dalg Co License No. 182 Business name Address Holtan, KS Signed Dale Astor Date 9-9-77 Authorized representative			

T 19
 R 12
 W EAW
 Sec 30
 NWSESE
 1/4 1/4 1/4 1/4