

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Coffey	Section SE 1/4 SE 1/4 NE 1/4	Section number 10	Township number T 19 S	Range number R 16 W																								
2. Distance and direction from nearest town or city: 1 W . 5 N			3. Owner of well: CURTIS BARTLETT																											
Street address of well location if in city: OF WAVERLY			City, state, zip code: WAVERLY, KANSAS 66871																											
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 2-9-77																										
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																										
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																										
				9. Casing: Material PVC Height: 29 in. or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 22 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2.74																										
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>TOP SOIL</td> <td>0</td> <td>3</td> </tr> <tr> <td>BROWN CLAY</td> <td>3</td> <td>8</td> </tr> <tr> <td>SANDSTONE</td> <td>8</td> <td>12</td> </tr> <tr> <td>LIMESTONE, grey</td> <td>12</td> <td>140</td> </tr> <tr> <td>Shale, grey</td> <td>140</td> <td>160</td> </tr> <tr> <td>SANDY shale, SANDSTONE</td> <td>160</td> <td>195</td> </tr> <tr> <td>Shale, grey</td> <td>195</td> <td>240</td> </tr> </tbody> </table>					From	To	TOP SOIL	0	3	BROWN CLAY	3	8	SANDSTONE	8	12	LIMESTONE, grey	12	140	Shale, grey	140	160	SANDY shale, SANDSTONE	160	195	Shale, grey	195	240	10. Screen: Manufacturer's name PUMCO Type PVC Dia. 5 Gauge 160 Length 60 Set between 160 ft. and 220 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/8		
					From	To																								
TOP SOIL	0	3																												
BROWN CLAY	3	8																												
SANDSTONE	8	12																												
LIMESTONE, grey	12	140																												
Shale, grey	140	160																												
SANDY shale, SANDSTONE	160	195																												
Shale, grey	195	240																												
				11. Static water level: <input type="checkbox"/> mo./day/yr. 160 ft. below land surface Date 2-9-77																										
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 3 g.p.m.																										
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>																										
				14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 29 inches above grade																										
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 13 ft.																										
				16. Nearest source of possible contamination: ft. 100 Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																										
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
(Use a second sheet if needed)																														
18. Elevation:		19. Remarks:		20. Water well contractor's certification:																										
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		owner will instal slab		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stander Data Co Inc 182 Business name RTI Holton, KS License No. <input type="checkbox"/> Address 2429 Date 2-12-77 Signed Dale Ashman Authorized representative																										

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5