


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Marion	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 4	Township number T 19 S R 2	Range number E W		
2. Distance and direction from nearest town or city: Street address of well location if in city: 4 miles north of Hillsboro			3. Owner of well: Lloyd Klassen R.R. or street: R.R. # 3 City, state, zip code: Hillsboro, Kans. 67063					
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 12 in. Completion date _____ Well depth 60 ft. 3/16/79					
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material plst Height: Above or below _____ Threaded _____ Welded gl Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 8 1/2 in. to 60 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gauge No. 0.322		
			10. Screen: Manufacturer's name Western Plastics Type PVC Dia. 8 1/2 Slot/gauze 3/32 Length 35' Set between 25 ft. and 60 ft. ft. and _____ ft. Gravel pack? Yes Size range of material 1/16 to 3/8			11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 3/16/79		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 110 g.p.m.			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: ft. 70' Direction SW Type corral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: (Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rader Drilling Co 1979 Business name License No. _____ Address Carlton, Kansas 67429 Signed Rader Date 4-18-79 Authorized representative				

T 19 S R 2 E W 4 NWSESW
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5