

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County MARION	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 28	Township number T 19 S R 3	Range number 3 E/W
2. Distance and direction from nearest town or city: 4 1/2 EAST +			3. Owner of well: MIKE RHODES		
Street address of well location if in city: 1 1/4 N of Highway			City, state, zip code: MARION KANSAS -		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date 3-31-76 Well depth 45 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	<input checked="" type="checkbox"/> Casing: Material plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 45 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____	
				10. Screen: Manufacturer's name Rabin-Tel - own slot Type PVC Dia. 6" Slot/gauze .064 Length 20' Set between 25 ft. and 45 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4	
LOAM		0	2	11. Static water level: _____ mo./day/yr. 27 ft. below land surface Date 3/31/76	
GREY CLAY		2	9	12. Pumping level below land surfaces: 42 ft. after 2 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8 g.p.m.	
LIGHT GREEN SHALE		9	35	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4/26/76	
DARK SHALE (WELLINGTON)		35	45	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: _____ ft. _____ Direction EAST Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name VALLEY Model number S-1267 HFD 37-13 Volts 230 Length of drop pipe 42 ft. capacity 8 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name License No. Address HESSON KANSAS Signed Paul Beuhler Date 4/27/76 Authorized representative	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

19
 3
 E
 28
 Sec
 1/4 1/4 1/4
 NW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5