

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Marion</b>	Fraction <b>NW 1/4 NE 1/4 NE 1/4</b>	Section number <b>8</b>	Township number <b>T 19 S R 4</b>	Range number <b>4</b>	<b>EW</b>
2. Distance and direction from nearest town or city: <b>1 M EAST of Cable in City of Marion 1/4 east.</b>			3. Owner of well: <b>Harlow Warneke</b> R.R. or street: <b>Rt 4</b> City, state, zip code: <b>Marion, Ks. 66861</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>9</b> in. Completion date <b>4-14-76</b> Well depth <b>50</b> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
<b>Top Soil</b>		<b>0</b>	<b>2</b>	9. Casing: Material <b>PVC</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>14</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>160</b> lbs./ft. Dia. <b>5</b> in. to <b>50</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>0231</b>		
<b>Lime Stone</b>		<b>2</b>	<b>22</b>	10. Screen: Manufacturer's name <b>Pumpco</b> Type <b>PVC</b> Dia. <b>5"</b> Slot/gauze <b>1/8</b> Length <b>15 ft.</b> Set between <b>35</b> ft. and <b>50</b> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>3/8</b>		
<b>Yellow + Red Shale</b>		<b>22</b>	<b>42</b>	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>15</b> ft. below land surface Date <b>4-14-76</b>		
<b>Water</b>		<b>42</b>	<b>-</b>	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
<b>Gray Rock</b>		<b>42</b>	<b>50</b>	13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____		
				14. Well head completion: <b>in garage</b> ____ Pitless adapter ____ Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: ft. <b>50 E</b> Direction <b>E</b> Type <b>Septic Tank</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
				18. Elevation:		
				19. Remarks: <b>Well To be inside of newly constructed garage. Pump NOT installed by my company.</b>		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Backhus Drilling 180</b> Business name License No. Address <b>Jampa Ks. 67483</b> Signed <b>Paul Backhus</b> Date <b>4-15</b> Authorized representative		

T 19 S R 4  
 Sec 8  
 NW 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5