USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Chase	Falls	SE 1/4 ~~NW~~ NW 1/4	29	T19S	R8E

Distance and direction from nearest town or city: 1/4 mi West of Lake
Street address of well location if in city: Road South Side

3 Owner of well: Walter Phillips.
Address: Cottonwood Falls Ks.

Locate with "X" in section below:



Sketch map:

4 Well depth: 49.6 ft. Date of completion 11/17/74
Well diameter 7" in.

5 [X] Cable tool [ ] Rotary [ ] Driven [ ] Dug [ ] Hollow rod [ ] Jetted [ ] Bored [ ] Reverse rotary

6 Use: [X] Domestic [ ] Public supply [ ] Industry [ ] Irrigation [ ] Air conditioning [ ] Commercial [ ] Test well [ ]

7 Casing: Material Plastic Height: above/~~below~~ Surface 1.4 ± 1/10
Threaded [ ] Welded [ ] Weight ___ lbs./ft.
Diam. 5" in. to 49.6 ft. depth Drive shoe? [ ] Yes [X] No
___ in. to ___ ft. depth

2

Type and color of material	From	To
Topsoil BlK	0	2
CL DK Brn.	2	22
Alluvium (Gravel)	22	25
Sh Gray Green. (Lower Eskridge)	25	30
Gray Lime (Neva) Hard Cap 1'	30	35
DK Gray Shale M (Salem Point)	35	40
DK Gray to Black (M) Shale	40	49.6
Lime section. Salem Point.	49.6	T.D.
Gravel Pack in Cave in (22'-25')		
~~Gr. Pack~~ To 20' (1/4"-5/8 Material)		
Perf Plastic 22'-49.6'		
Cement 4 Sacks. Had to run.		
7" Surface to 31 Feet Pulled.		
Packed & Cemented. Plastic		
(use a second sheet if needed)		

8 Screen:
Manufacturer Sunflower Styrene
Type Plastic Dia. 5"
Slot/gauze ___ Length 25 feet
Set between 22 ft. and 49 ft. 6
Fittings:
Gravel pack [ ] Yes [X] No Size range of material ___

9 Static water level:
24.8 ft. below land surface Date 11/17/74

10 Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 10-12 g.p.m.

11 Water sample submitted:
[ ] Yes [X] No Date 11/17/74

12 Well head completion: Closed In (1.4 feet)
[ ] Pitless adapter [X] Inches above grade

13 Well grouted? [X] Yes [ ] No
[X] Neat cement [ ] Bentonite [ ] ___
Depth: From 20 ft. to .6 ± 1/10

14 Nearest source of possible contamination: Creek
ft. 50 Direction South Type ___
Well disinfected upon completion? [X] Yes [ ] No

15 Pump: [X] Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.m.p.
Type:
[ ] Submersible [ ] Turbine
[ ] Jet [ ] Reciprocating
[ ] Certrifugal [ ] Other

16 Remarks: elevation

Topography:
[ ] Hill
[ ] Slope
[ ] Upland
[X] Valley

High Aera.
Aprox 25-30" Above Creek

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
James C McNee 203
Business name License No.
Address Cottonwood Falls Ks.
Signed [signature] Date 11/26/74
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H