USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Washington	Fraction: X NE 1/4 NE 1/4 NE 1/4	Section number: 26	Township number: T 1 (S)	Range number: R 1 (E) W

2. Distance and direction from nearest town or city: 1 West 6 North 1 east of Haddam
Street address of well location if in city:

3. Owner of well: Rodney Arbuthnot
R.R. or street: R.R.
City, state, zip code: Haddam, Kans. 66944

4. Locate with "X" in section below:



Sketch map:

6. Bore hole dia. 8 in. Completion date 9-20-79
Well depth 242 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material PVC
Threaded ___ Welded ___
RMP ___ PVC ___
Dia 5 in. to 242 ft. depth
Dia. ___ in. to ___ ft. depth
Height: Above or below Surface 12 in.
Weight 200 lbs./ft.
Wall Thickness: inches or gage No. .200

5. Type and color of material	From	To
soil Top	0	2
Clay Brown	2	6
Limestone + Clay Layers	6	16
shale yellow	16	30
shale Gray	30	86
shale Tan	86	95
sand rock	95	124
shale Gray	124	170
shale Brown	170	175
sand Rock	175	180
limestone rock	180	182
shale Brown	182	206
sand Rock	206	242
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Plastic NSF approved
Type Plastic Dia. 5 in
Slot/gauze .030 Length 20
Set between 220 ft. and 240 ft.
___ ft. and ___ ft.
Gravel pack? Yes Size range of material well gravel

11. Static water level: mo./day/yr.
157 ft. below land surface Date 9-20-79

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 75+ g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes X No Date ___

14. Well head completion: capped
___ Pitless adapter ___ Inches above grade

15. Well grouted? Yes
With: ___ Neat cement ___ Bentonite X Concrete
Depth: From 0 ft. to 20 ft.

16. Nearest source of possible contamination: none
ft. ___ Direction ___ Type ___
Well disinfected upon completion? X Yes ___ No

17. Pump: X Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
___ Submersible ___ Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation: 1500
Topography:
___ Hill
___ Slope
✓ Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Blue Valley Drilling 234D
Business name License No.
Address Blue Rapids, Ks 66411
Signed Gerald Strader Date 8-13-79
Authorized representative

T 1 R 1 (E) W Sec 26 1/4 1/4 1/4 NENENE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5