

10

VJD

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SE 1/4 - NE 1/4 - SE 1/4 *dad*

1. Location of well: County NEMANA		Fraction NE-SE NE 1/4 NW 1/4 SE 1/4	Section number 1	Township number T 1 S R 14 E/W	Range number 14
2. Distance and direction from nearest town or city: 5 1/2 N		3. Owner of well: State of Kansas (Point of Entry)			
Street address of well location if in city: Sabetha		R.R. or street: R.R.			
		City, state, zip code: Sabetha, KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 5-18-78	
				Well depth 90 ft. 90 to 10' / 8' to 90	
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC plus Weight 2.24 lbs./ft. Dia. 5 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258	
5. Type and color of material		From	To	10. Screen: Manufacturer's name Pumped	
Top Soil		0	1	Type PVC Dia. 5 in.	
Brown Clay		1	23	Slot/gauze 080 Length 20	
Gray Shale (Red-Greenish)		23	55	Set between 48 ft. and 68 ft.	
Yellow limestone		55	58	Gravel pack? yes Size range of material 1/4 x 1/8	
Gray Shale		58	61	11. Static water level: 45 ft. below land surface Date 5-18-78	
Yellow & Gray Shale		61	80	12. Pumping level below land surfaces: Per Test	
				____ ft. after ____ hrs. pumping ____ g.p.m.	
				____ ft. after ____ hrs. pumping ____ g.p.m.	
				Estimated maximum yield 30 g.p.m.	
				13. Water sample submitted: no./day/yr.	
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
				14. Well head completion: Top Cap	
				Pitless adapter 24 Inches above grade	
				15. Well grouted? yes	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From 5 ft. to 25 ft.	
				16. Nearest source of possible contamination:	
				ft. 100 Direction North Type Lateral	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name Jacuzzi	
				Model number 554B HP 1/2 Valfs 230	
				Length of drop pipe 70 ft. capacity 10 g.p.m.	
				Type:	
				<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: pt 1100		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
19. Remarks: owner to install slab.		STRAIDER Dalg Co Inc 182			
		Business name STRAIDER Dalg Co Inc License No.			
		Address Rt 1 Holton, KS			
		Signed Dale Ashman Date 5-30-78			
		Authorized representative			

(Use a second sheet if needed)

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 1077 R = 1055

140
NE NW SE
1/4 1/4 1/4