



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

CCC

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Brown	Township name Morrill	Fraction SW 1/2 SW 1/4	Section number 10	Town number 1S	Range number 15E	
Distance and direction from nearest town or city: 3 mi. North			3 Owner of well: Vernon D. Esslinger				
Street address of well location if in city: 2nd St Morrill			Address: R1 Box 148 Morrill, KS.				
Locate with "X" in section below: 			Sketch map: 			4 Well depth: 110 ft. Date of completion Well diameter 8 in. 5-14-75	
2 Type and color of material			From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
					7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. 2.33 lbs./ft. 0 in. to 110 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 0 in. to 0 ft. depth		
					8 Screen: Manufacturer Pumped Type PVC Dia. 5" Slot/gauze 40' Set between 0 ft. and 0 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8"		
					9 Static water level: No measurement 0 ft. below land surface Date 5-14-75		
Top Soil			0 3		10 Pumping level below land surfaces: Air Test 0 ft. after 0 hrs. pumping 0 g.p.m. 0 ft. after 0 hrs. pumping 0 g.p.m. Estimated maximum yield 20 g.p.m.		
YELLOW CLAY			3 10		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 5-14-75		
RED CLAY			10 13		12 Well head completion: <input type="checkbox"/> Pitless adapter 24 inches above grade		
YELLOW CLAY			13 20		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
Gray CLAY			20 30		14 Nearest source of possible contamination: ft. 0 Direction NORTH Type SEPTIC TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
" "			30 33		15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
White Limestone			33 34		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. Inc. Business name _____ License No. _____ Address R1-75N, Holton, KANS Signed Strader Date 6/4/75 Authorized representative		
Gray Shale			34 36				
Yellow lime			36 49				
Gray Shale			49 65				
" Lime			65 68				
Black Shale			68 75				
White Lime (water)			75 76				
Blue Lime (106 PPM)			76 77				
Grey Lime			77 79				
" (use second sheet if needed)			79 90				
16 Remarks: elevation 1125 Blue Shale Grey Lime			90-95 95-110				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

BR = 1092