

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.



WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well: County **Doniphan** Township name **IOWA** Fraction **E 1/2 SE 1/4** Section number **17** Town number **1 S** Range number **19 E**

Distance and direction from nearest town or city: **2 SW White Cloud KS** Owner of well: **P.H.S.**  
Street address of well location if in city: Address: **White Cloud, KANS**

Locate with "X" in section below:  Sketch map: 

4 Well depth: **77** ft. Date of completion **4-7-75**  
Well diameter **6"** in.

5  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

6 Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Commercial  
 Test well

7 Casing: Material **PVC** Height: above/below  
Threaded  Welded  Surface **24** in.  
Diam. Weight **233** lbs./ft.  
\_\_\_ in. to \_\_\_ ft. depth Drive shoe?  Yes  No  
\_\_\_ in. to \_\_\_ ft. depth

2	Type and color of material	From	To
	TOP SOIL	0	5
	BROWN CLAY	5	30
	Blue CLAY	30	55
	COURSE SAND-PEA GRAVEL	55	60

*See test hole log #2 (DB=67') from Indian Health Service filed under "Public Supply"*

*0-60' top soil  
6-40' blue clay  
40-55' blue clay  
52-59' coarse sand  
59-67' coarse sand  
67-72' blue shale  
72'*

(use a second sheet if needed)

8 Screen: Manufacturer **Pump Co.**  
Type **PVC** Dia. **5"**  
Slot/gauze Length **5'**  
Set between **55** ft. and **60** ft.  
Fittings: Gravel pack  Yes  No Size range of material \_\_\_

9 Static water level: **18** ft. below land surface Date **4-7-75**

10 Pumping level below land surfaces: **Air Test**  
\_\_\_ ft. after \_\_\_ hrs. pumping \_\_\_ g.p.m.  
\_\_\_ ft. after \_\_\_ hrs. pumping \_\_\_ g.p.m.  
Estimated maximum yield **60** g.p.m.

11 Water sample submitted:  Yes  No Date **4-8-75**

12 Well head completion:  Pitless adapter  Inches above grade

13 Well grouted?  Yes  No  
 Neat cement  Bentonite   
Depth: From \_\_\_ ft. to \_\_\_ ft.

14 Nearest source of possible contamination: ft. **4000** Direction **NORTH** Type **SEPTIC TANK**  
Well disinfected upon completion?  Yes  No

15 Pump:  Not installed  
Manufacturer's name \_\_\_  
Model number \_\_\_ HP \_\_\_ Volts \_\_\_  
Length of drop pipe \_\_\_ ft. capacity \_\_\_ g.p.m.  
Type:  Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

16 Remarks: elevation **1025?** **Plotted on map on valley all at elev. 925**  
**This test well for Quality of water samples will be pulled & plugged LATER**  
Topography:  Hill  Slope  Upland  Valley

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**Strader Drilling Co. Inc. #182**  
Business name License No. **BRI-N75 Holton, KANS.**  
Address **Osage Avenue** Date **4-10-75**  
Signed **[Signature]** Authorized representative