

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County WASHINGTON	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 14	Township number T 1 S R 2 (E/N)	Range number
2. Distance and direction from nearest town or city: 8 3/4 N			3. Owner of well: WILLIAM FRAGER		
Street address of well location if in city: MORROWVILLE			R.R. or street: ROUTE 2		
			City, state, zip code: MORROWVILLE, KANS 66958		
4. Locate with "X" in section below:		Sketch map:			
N					
W					
S					
5. Type and color of material		From	To	6. Bore hole dia. 8 in. Completion date 11-18-77 Well depth 160 ft.	
TOPSOIL		0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
BROWN CLAY		3	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
SANDROCK		10	12	9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258	
BROWN CLAY		12	27	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 Slot gauze 1/16 Length 20' Set between 140 ft. and 160 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 4x4	
SANDROCK		27	40	11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 11-18-77	
BLUE CLAY		40	55	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.	
SANDROCK		55	75	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
GRAY CLAY		75	91	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
RED CLAY		91	132	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
BLUE CLAY		132	136	16. Nearest source of possible contamination: HOG ft. 70 Direction WEST Type LOT Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
SANDROCK		136	160	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
STOP		160			
(Use a second sheet if needed)					
18. Elevation: 1510 ft		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox + Sons Inc 258 Business name License No. Address CLIFTON, KANS 66937 Signed Nancy Cox Date 12-1-77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
W
E
14
1/4
1/4
1/4
S
W
N
E