

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Marshall	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 30	Township number T 1 S R 7 E	Range number E/W
2. Distance and direction from nearest town or city:	Herkimer 3 1/2 mi north and 3 mi east on north side road				
Street address of well location if in city:	Mid Paul N. Schutte R 7 D Marysville Kans				
4. Locate with "X" in section below:	Sketch map: 				
5. Type and color of material	From	To	6. Bore hole dia. 10 in. Completion date Well depth 60 ft. 1-11-79		
top soil (Black)	0	5	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Clay, yellow	5	38	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Rock: yellow limestone	38	49	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 5 in. to 60 ft. depth Wall Thickness: 20 inches Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 207		
Shale Blue	49	60	10. Screen: Manufacturer's name M.P.I. Type P.V.C. Dia. 5 Slot/gauge 040 Length 20 Set between 38 ft. and 58 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 1/4		
			11. Static water level: 40 ft. below land surface Date 1-11-79 mo./day/yr.		
			12. Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 40 g.p.m.		
			13. Water sample submitted: ___ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ___		
			14. Well head completion: NA ___ Pitless adapter ___ Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> 1-g With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 16 ft. to 6 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction S. east Type Septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No ___		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. 237 Business name Blue Rapids KS License No. ___ Address Harold Strader Date 2-6-79 Signed Harold Strader Authorized representative		

1-11-79
 R 7 D
 W 30
 NW 1/4 SE 1/4