

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>MARION</b>	Fraction <b>NE 1/4 NE 1/4 SW 1/4 E</b>	Section number <b>24</b>	Township number T <b>20</b> S R <b>1</b> <b>(E)NW</b>	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
2. Distance and direction from nearest town or city: <b>3 N - 4 E - 1/2 N</b>			3. Owner of well: <b>JACK BYRD</b>			
Street address of well location if in city: <b>of GOESSEL</b>			R.R. or street:			
City, state, zip code: <b>Hillsboro RR #2 KNS</b>						
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>6-17-77</u> Well depth <u>75</u> ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Loam to clay			0	5'	9. Casing: Material <u>plastic</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2.28</u> lbs./ft. Dia. <u>5</u> in. to <u>25</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>25</u> ft. depth gage No. <u>2265</u>	
Clay - Brown - w. fine sand			5	15	10. Screen: Manufacturer's name <u>Kem-Tech - own slot</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1046</u> Length <u>20'</u> Set between <u>55</u> ft. and <u>75</u> ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8-1/4</u>	
Med course sand & clay			15	20	11. Static water level: mo./day/yr. <u>+ 24'</u> ft. below land surface Date <u>6-20/77</u>	
Alkali			20	21	12. Pumping level below land surfaces: <u>60</u> ft. after <u>72</u> hrs. pumping <u>28</u> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <u>28</u> g.p.m.	
Clay - grey to light green & dark with 1 layer alkali			21	30	13. Water sample submitted: mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>6-27/77</u>	
Clay - grey (soft shale)			30	35'	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>24</u> inches above grade	
Shale - dark (1 layer lime rock)			35	45'	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>15</u> ft. to <u>0</u> ft.	
Shale - grey			45	50	16. Nearest source of possible contamination: ft. <u>60</u> Direction <u>west</u> Type <u>Creek</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Shale - grey - layered lime rock			50	60	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Shale - " to dark			60	65'	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>PAUL'S INC #175</u> Business name License No. Address <u>HESSTON, KNS</u> Signed <u>Paul Benoit</u> Date <u>6/27/77</u> Authorized representative	
Shale - dark layered			65	75'		
"Faults" - 43'						
61'						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Well "Static" flows over top approx <u>10 GPM</u>				

20 1 24 NE/SE  
 T R W E  
 Sec 24  
 1/4 1/4 24

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5