

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Marion	Fraction Ne 1/4 Sec 14 Se 1/4	Section number 28	Township number T 20 S R 1	Range number 1
2. Distance and direction from nearest town or city: 2 1/4 N 1 E				3. Owner of well: Ralph Janzen		
Street address of well location if in city: Gossett				R.R. or street: Hillsboro BR2		
				City, state, zip code: Hillsboro KS. 67063		
4. Locate with "X" in section below:				Sketch map:		
				6. Bore hole dia. 10-2 in. Completion date 7-2-76 Well depth 120 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.42 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 125F		
5. Type and color of material				From	To	10. Screen: Manufacturer's name M.P.L.
Top Soil				0	2	Type PVC Dia. 5
Yellow Clay + Shale				2	24	Slot/gauze 5 Length 23
Blue Shale				24	60	Set between 8.5 ft. and 20 ft. 110 ft. and 110 ft.
Some Water				60		Gravel pack? <input checked="" type="checkbox"/> Size range of material 30
Blue Shale				60	87	11. Static water level: 80 ft. below land surface Date _____ mo./day/yr.
Some Water				87		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Blue Shale				87	110	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Water				110		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
Blue Shale				110	120	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: Dairy ft. 200 Direction W Type Perm Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks: owner to run concrete slab around well 4' x 4' x 4"		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhoe Drg. 100 Business name _____ License No. _____ Address Tampa, FL Signed Paul Walker Date _____ Authorized representative 7-11-76		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 20 S R 1
 Sec 28 NE SE SE
 1/4 1/4 1/4