


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

C 5/2 SENE

1 Location of well:	County Marion	Township name Center	Fraction Marion County Lake	Section number 10	Town number 20	Range number 4E	
Distance and direction from nearest town or city: Marion			3 Owner of well: C. E. Coleman				
Street address of well location if in city: 2 mi. SE			Address: Lot 1 Lakeview Addition Marion County Lake 66861				
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 65 ft. Date of completion: Sept 9, 1976 Well diameter 9 in.	
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
			Yumbo		3	7 Casing: Material Pvc Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. Diam. 5 Weight 200 lbs./ft. 65 in. to 65 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No	
			Soap Stone	10	13	8 Screen: Manufacturer plus Type plus Dia. 5 1/2 Slot/gauze 3/8" Length 20 Set between 45 ft. and 65 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ---	
			Yumbo	7	20	9 Static water level: 50 ft. below land surface Date Sept 9, 1976	
			Soap Stone	12	32	10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
			Red Rock	8	40	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
			Soap Stone	10	50	12 Well head completion: <input type="checkbox"/> Pitless adapter 10 inches above grade	
Yumbo	5	55	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From top 20 ft				
Yumbo	10	65	14 Nearest source of possible contamination: MHC 60 ft. Direction south Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
(use a second sheet if needed)					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Duck Model number ____ HP 1/2 Volts 220 Length of drop pipe 65 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
					16 Remarks: elevation		
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Shirley Waterwell 278 Business name Marion Co License No. ____ Address Marion, Mo Signed Walter Shirley Date Sept 10, 1976 Authorized representative		
					Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

80 4E 10 C 5/2 SENE 61