

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Marion County Lake

1. Location of well:		County Marion	Fraction SW 1/4 NE 1/4 NW 1/4	Section number 10	Township number T 20S	Range number S R 4E	E/W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: Don Patry R.R. or street: City, state, zip code: Glenn, Kansas 66857			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date Nov 30 78 Well depth 75 ft.			
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gumbo		0		4		<input checked="" type="checkbox"/> Casting: Material Plas Height: Above or below Threading: <input type="checkbox"/> Threaded <input type="checkbox"/> Welded Surface: 72 in. RMP: <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight: 100 lbs./ft. Dia. 5 in. to 75 ft. depth Well thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Page No. 200	
H Lime		4		34		<input checked="" type="checkbox"/> Screen: Manufacturer's name Standard Standard Plastic pipe with perforations Type Plas Dia. <input checked="" type="checkbox"/> 5 in. Slot/gauze 3/16 Length 20 ft Set between 55 ft. and 75 ft.	
Soap Stone		30		40		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4	
Lime		40		50		11. Static water level: _____ mo./day/yr. 40 ft. below land surface Date Nov 30 78	
Bed Rock		50		65		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Lime		65		70		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 10 Inches above grade	
						15. Well grouted? <input checked="" type="checkbox"/> A With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 90 ft.	
						16. Nearest source of possible contamination: ft. 300 Direction North Type Septic Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Schmitt Water Well 278 Business name _____ License No. _____ Address Marion, Kansas Signature William Schmitt Date May 1 79 Authorized representative			

T 20S
 R 4E
 W 10
 Sec 10
 SW 1/4 NE 1/4 NW 1/4