

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County Marion	Fraction NW 1/4 SE 1/4 Sec 4	Section number 32	Township number T 20 S R 4 (E)N	
<input checked="" type="checkbox"/> Distance and direction from nearest town or city: Street address of well location if in city:	in city Marion		3. Owner of well: Hill Top Maner R.R. or street: 1591 E Hawcreece City, state, zip code: Marion Mo.		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. 5 in. Completion date 8-20-77 Well depth 92 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Red Clay		2	5	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1 1/2 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 30 lbs./ft. Dia. 5 in. to 92 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 23-R	
lime Stone		5	36	10. Screen: ASTM Type PVC Dia. 5 1/2 Slot/gauze 1/4 Length 20 Set between 60 ft. and 20 ft. 22 ft. and 22 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20	
yellow Shale		36	54	11. Static water level: _____ mo./day/yr. 22 ft. below land surface Date 8-20-77	
lime Stone		54	62	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Some Water		62	63	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
lime Stone		63	P5	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
Water		P5	P6	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Gray Rock		P6	92	16. Nearest source of possible contamination: _____ ft. no Direction NW Type line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: owner to run concrete slab around well 4'x4'x4"			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhus Drdg 100 Business name _____ License No. _____ Address Topeka, Mo. Signed Paul Backhus Date 8-23-77 Authorized representative	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

20-4-C
 32
 NWSE
 1/4 1/4 1/4