

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Chase	Township name Cottonwood	Fraction SE 1/4, S29-T20R6	Section number 29	Town number T20S	Range number R6E
Distance and direction from nearest town or city: 1 North 1/2 East of				3 Owner of well: J. Lee Byram			
Street address of well location if in city: Cedar point				Address: Cedar point Kansas			
Locate with "X" in section below:		Sketch map:					
<div style="text-align: center;">N W E S 1 Mile</div>		SE 1/4 of SW 1/4 of T20R6 of S29, T20, R6					
2		Type and color of material		From	To	4 Well depth: 60 ft. Date of completion 3-27-75 Well diameter 8 in.	
		Over Borden		0	5	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		Red gumbo		5	8	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
		Flint Rock		8	10	7 Casing: Material Plastic Height: above /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 6 1/2 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 6 1/2 ft. depth	
		Flint Rock		10	15	8 Screen: Manufacturer Sunflower Plastic Type 200 Dia. 5 5/16 gauze 1/16 Length 20' Set between 35 ft. and 5" ft. 55' Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8	
		yellow shale		15	31	9 Static water level: 30 ft. below land surface Date 3-27-75	
		yellow shale		31	40	10 Pumping level below land surfaces: 35 ft. after 6 hrs. pumping 15 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 20 g.p.m.	
		gray shale		40	55	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
		Red rock		55	60	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
		water at 40ft				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 5 ft. to 28 ft.	
						14 Nearest source of possible contamination: ft. 100 Direction East Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number ____ HP 1/2 Volts 230 Length of drop pipe 45 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Richmond Well Drilling 222 Business name Richmond License No. 222 Address Box 14 Marion Signed Richmond Date 3-27-75 Authorized representative	