

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Chase	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 18	Township number T 20 S R 8 E	Range number
2. Distance and direction from nearest town or city: 45 - 1/2 W			3. Owner of well: Jim Fink		
Street address of well location if in city: Cottonwood Falls			R.R. or street: Cottonwood Falls Ks.		
			City, state, zip code: 66845		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 7/31/78 Well depth 39' ft.	
		<p style="text-align: center;">N</p> <p style="text-align: center;">Hole 3</p>		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material _____ Height: Above or _____ Threaded _____ Welded _____ Surface 12" in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 8 in. to 39' ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. 3/8	
				10. Screen: Manufacturer's name _____ Type PVC Dia. 8" Slot/Screen Shop Length 20' Set between 19' ft. and 39' ft. _____ ft. and _____ ft. Gravel pack? No Size range of material _____	
CL DK Bnn		0	3	11. Static water level: _____ mo./day/yr. 11' ft. below land surface Date 7/31/78	
CL with Flint Gravel		3	11	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 5-6 g.p.m.	
Clay Shale yellow + Green		11	19	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Lime Gray Med.		19	22	14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade	
Broken Lime weak Gray		22	30	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 11 ft.	
Shale Variegated Color		30	39	16. Nearest source of possible contamination: ft. 250' Direction E Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
TD 39 Hard Lime				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		Water seems to be fairly soft + good quality.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. McNee Drilling 203 Business name _____ License No. _____ Address Cottonwood Falls Signed [Signature] 8/4/78 Authorized representative	

T 20 S R 8 E
 Sec 18 SE 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5