


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Marion	Township name Catlin	Fraction SE SW SE 40 acres	Section number 32	Town number 21-S	Range number 3-E	
Distance and direction from nearest town or city: 1/4 Mile West of Peabody			3 Owner of well: Jewell Davis Rt. 2 Peabody, Kansas 66866				
Street address of well location if in city:			Address:				
Locate with "X" in section below: 			Sketch map: Fraction SE 1/4 of the SW 1/4 of The SE 1/4 of section 32, T21S R3E			4 Well depth: 64 ft. Date of completion 1-3-75 Well diameter 8 in.	
			5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			7 Casing: Material Plastic <input type="checkbox"/> above <input checked="" type="checkbox"/> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 7 1/2 in. Diam. 5" Weight 147 lbs./ft. 100 5 in. to 64 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No 5 in. to 64 ft. depth			8 Screen: Manufacturer Sunflower Plastic Type 200 Dia. 5 Slot/gauze 1/16 Length 20 ft. Set between ft. and ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8	
2 Type and color of material			From		To		
Overburden			0		5		
Sand & Clay			5		22		
Blue Shale			22		64		
Water 45 ft.							
					9 Static water level: 25 ft. below land surface Date 1-3-75		
					10 Pumping level below land surfaces: 45 ft. after 6 hrs. pumping 18 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
					11 Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date 		
					12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade 12		
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 35 ft. to 3 ft.		
					14 Nearest source of possible contamination: ft. 75ft. direction East Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Valley Pump Model number MF2052P 1/2 Volts 230 Length of drop pipe 52 ft. capacity 12 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Richmond Well Drilling 222 Business Rt. 4 Marion License No. Address Signed Rich Richmond Date 1-3-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5