


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Doyle

1. Location of well: County <u>Marion</u> Fraction <u>1/4 Sec 1/4 Sec 1/4</u> Section number <u>25</u> Township number <u>T 21 S</u> Range number <u>R 4 E</u>	
2. Distance and direction from nearest town or city: <u>4 S 1 W 1/8 N</u> Street address of well location if in city: <u>Florence</u> 3. Owner of well: <u>Bob Bruner</u> R.R. or street: <u>RR1</u> City, state, zip code: <u>Florence Mo. 66851</u>	
4. Locate with "X" in section below: Sketch map: 	6. Bore hole dia. <u>7-7</u> in. Completion date <u>10-31-78</u> Well depth _____ ft.
	7. <input checked="" type="checkbox"/> Cable tool _____ Rotary _____ Driven _____ Dug _____ _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary
5. Type and color of material	8. Use: <input checked="" type="checkbox"/> Domestic _____ Public supply _____ Industry _____ _____ Irrigation _____ Air conditioning _____ Stock _____ _____ Lawn _____ Oil field water _____ Other _____
	9. Casing: Material <u>Styrene</u> Height: Above or below _____ Threaded _____ Welded _____ Surface <u>72</u> in. RMP _____ WVC _____ Weight _____ lbs./ft. Dia. <u>5</u> in. <u>86</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>200 Wall</u>
Top Soil	10. Screen: Manufacturer's name _____ <u>Jess + Howell</u> Type <u>Styrene</u> Dia. <u>5 1/4</u> Slot/gauze _____ Length <u>98</u> Set between <u>30</u> ft. and <u>98</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4-1/2</u>
Yellow Clay	11. Static water level: _____ mo./day/yr. <u>25</u> ft. below land surface Date <u>10-31-78</u>
Lime Stone	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Yellow Shale	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Some Water	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
Lime Stone	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>3</u> ft. to <u>13</u> ft.
Gray Rock	16. Nearest source of possible contamination: _____ ft. _____ Direction <u>NE</u> Type <u>septic tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
Lime Stone	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____
Water	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Barckhus Dig. 180</u> Business name _____ License No. _____ Address <u>Tampa Mo.</u> Signed <u>Paul Barckhus</u> Date <u>11-77</u> Authorized representative
Gray Rock	
(Use a second sheet if needed)	
18. Elevation:	19. Remarks:
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley	

T 21 S R 4 E Sec 25