

OFFICE USE ONLY

T

8

R

8

EW

SEC

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

SW 1/4

1 LOCATION OF WATER WELL  
 County: Chase Fraction: SW 1/4 SW 1/4 SW 1/4 Section Number: 3 Township Number: T 21 S Range Number: R 8 EW  
 Distance and direction from nearest town or city? 25-1/2 E Street address of well if located within city? B2227R KS.


2 WATER WELL OWNER: Dale Starkey  
 RR#, St. Address, Box #: RR- Board of Agriculture, Division of Water Resources  
 City, State, ZIP Code: Cottonwood Falls KS 66845 Application Number:

3 DEPTH OF COMPLETED WELL: 90 ft. Bore Hole Diameter: 10 in. to 11 ft., and 8 in. to 90 ft.  
 Well Water to be used as:  
 Domestic  Feedlot  Oil field water supply  Air conditioning  Injection well  
 Irrigation  Industrial  Lawn and garden only  Dewatering  Other (Specify below)  
 Observation well  
 Well's static water level: 10 ft. below land surface measured on 4 month 11 day 79 year  
 Pump Test Data: Well water was \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ gpm  
 Est. Yield 2 gpm: Well water was \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ gpm

4 TYPE OF BLANK CASING USED:  
 Steel  RMP (SR)  Concrete tile  Casing Joints: Glued \_\_\_\_\_ Clamped \_\_\_\_\_  
 PVC  ABS  Asbestos-Cement  Other (specify below)  Welded \_\_\_\_\_  
 Fiberglass  Threaded \_\_\_\_\_  
 Blank casing dia: 6 in. to 10 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
 Casing height above land surface: 12 in., weight \_\_\_\_\_ lbs./ft. Wall thickness or gauge No: 3/8  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 PVC  Asbestos-cement  
 Steel  Stainless steel  Fiberglass  RMP (SR)  Other (specify) \_\_\_\_\_  
 Brass  Galvanized steel  Concrete tile  ABS  None used (open hole)  
 Screen or Perforation Openings Are:  
 Continuous slot  Mill slot  Gauzed wrapped  Saw cut  None (open hole)  
 Louvered shutter  Key punched  Wire wrapped  Drilled holes  
 Torch cut  Other (specify) \_\_\_\_\_  
 Screen-Perforation Dia: 6 in. to 90 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
 Screen-Perforated Intervals: From 11 ft. to 86 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Gravel Pack Intervals: From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

5 GROUT MATERIAL:  Neat cement  Cement grout  Bentonite  Other \_\_\_\_\_  
 Grouted Intervals: From X0 ft. to 10 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 What is the nearest source of possible contamination:  
 Septic tank  Cess pool  Sewage lagoon  Fuel storage  Abandoned water well  
 Sewer lines  Seepage pit  Feed yard  Fertilizer storage  Oil well/Gas well  
 Lateral lines  Pit privy  Livestock pens  Insecticide storage  Other (specify below) Creek  
 Watertight sewer lines  
 Direction from well: East How many feet: 100? Water Well Disinfected? Yes  No   
 Was a chemical/bacteriological sample submitted to Department? Yes \_\_\_\_\_ No  If yes, date sample was submitted \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year: Pump Installed? Yes \_\_\_\_\_ No   
 If Yes: Pump Manufacturer's name \_\_\_\_\_ Model No. \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
 Depth of Pump Intake \_\_\_\_\_ ft. Pumps Capacity rated at \_\_\_\_\_ gal./min.  
 Type of pump:  Submersible  Turbine  Jet  Centrifugal  Reciprocating  Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was  constructed,  reconstructed, or  plugged under my jurisdiction and was completed on 5 month 12 day 1979 year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 203  
 This Water Well Record was completed on 12/12 month 17 day 79 year under the business name of McNee Drilling by (signature) J. McNee

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:  
  

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	11	CL w Flint Gravel Ben	68	90	Lime Shale White
11	13	Sh Lt Gray.	90	94	Gyp.
13	33	Siltstone + Shale Gray			
33	38	Lime w Calc Sh Gray.			
38	40	Blk Shale			Plug Back to 90
40	41	Lime			
41	44	Bkly Blk Sh.			Portland Cement.
44	54	Lime + Sh. Gray.			
54	55	Dense Lime			
55	68	Siltstone Gray.			
68	93	Calc Sh Gray.			

 ELEVATION: \_\_\_\_\_

Depth(s) Groundwater Encountered 1. 33 ft. 2. \_\_\_\_\_ ft. 3. \_\_\_\_\_ ft. 4. \_\_\_\_\_ ft. (Use a second sheet if needed)  
 INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.