

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 10	Township number T 22 S	Range number R 1-E	E/W
2. Distance and direction from nearest town or city: From WATSON 2 N AND 3 1/2 W Street address of well location if in city:				3. Owner of well: WARREN CUMMINGS R.R. or street: RR #3 City, state, zip code: NEWTON KANS 67114			
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 2 in. Completion date 10-7-78 Well depth 99 ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material				9. Casing: Material ABS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 99 ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. 1200			
				10. Screen: Manufacturer's name SUNFLOWER PLASTIC PIPE Type 200 Dia. 5 11 Slot gauze 1/8 Length 30 Set between 1/8 ft. and 99 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2			
CLAY				11. Static water level: _____ mo./day/yr. 16 ft. below land surface Date 10-7-78			
CLAY + FINE SAND				12. Pumping level below land surfaces: 69 ft. after 4 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.			
BROWN GLAY				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
DRAY GLAY				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 16 Inches above grade			
BLD SHALE				15. Well grouted? <input checked="" type="checkbox"/> YES With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 14 ft.			
SHALE WITH SOME GYPSUM ROCK				16. Nearest source of possible contamination: ft. 170 Direction NW Type HOG BORN Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
SOFT SHALE + DRAY GLAY				17. Pump: _____ Not installed Manufacturer's name Goulds Model number 10B10741A HP 3/4 Volts 230 Length of drop pipe 85 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other			
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN SUPPLY 362 business name License No. Address 300 W 22ND NEWTON Signed Burt Schmidt Date 10-7 Authorized representative			
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 22 S
 R 1 E
 S 10
 SE SE SW
 1/4 1/4 1/4