

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 18	Township number T 22 S R 1 E	Range number 1
2. Distance and direction from nearest town or city: Street address of well location if in city: 8 LEONARD CT			3. Owner of well: BURLEY STARKS R.R. or street: 8 LEONARD CT City, state, zip code: NEWTOWN KS 67114			
4. Locate with "X" in section below:		Sketch map: W B ROADWAY LEONARD CT			6. Bore hole dia. 12 in. Completion date 9-27-78 Well depth 55 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.50 lbs./ft. Dia. 5 in. to 55 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 200	
					10. Screen: Manufacturer's name J&J Type RMP Dia. 5 Slot/gauze 20 Length 20 Set between 35 ft. and 33 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 42-44	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 9-27-78	
					12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 50 Direction S Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Paraflo Model number <input type="checkbox"/> HP 1/2 Volts 115 Length of drop pipe 45 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D & G Well Service 2-11 Business name License No. Address 413 N. 24th St. Newton, KS Signed D & G Well Service Date 10-30-78 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

22-1018
1/4 NW 1/4 SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5