

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County HARVEY		Fraction NE 1/4 NE 1/4 NW 1/4		Section number 18		Township number T 22 S R 1 E 1	
2. Distance and direction from nearest town or city: Street address of well location if in city: 901 TRINITY				3. Owner of well: R HARBUCK R.R. or street: 901 TRINITY DR City, state, zip code: NEWTOWN KS			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: W SCHOOL 12TH ST TRINITY DR WELL → X				6. Bore hole dia. 10 in. Completion date 9-20-78 Well depth 48 ft.			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
From To				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
TOP SOIL				9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1-50 lbs./ft. Dia. 5 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200			
CLAY RED				10. Screen: Manufacturer's name J & J			
CLAY SANDY				Type Rimf Dia. 5 Slot/gauze .26 Length 20 Set between 28 ft. and 48 ft. ft. and <input type="checkbox"/> ft.			
SAND FINE TO COARSE				Gravel pack? YES Size range of material 1/8 to 1/4			
				11. Static water level: <input type="checkbox"/> mg./day/yr. 30 ft. below land surface Date 9-20-78			
				12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.			
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade			
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: Storm ft. 50 Direction N Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Frimpeco Model number <input type="checkbox"/> HP 1/2 Volts 230 Length of drop pipe 40 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D & R Well Service 211 Business name License No. Address 4230 3rd Street, Newton, KS Signed [Signature] Date 10-30-78 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

22-1018 newnw
T
R
W
E
S
C
1/4 1/4 1/4