

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 820-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>Greenwood</u> Fraction <u>NE 1/4 NW 1/4 SW 1/4</u> Section number <u>1</u> Township number <u>T 22 S</u> Range number <u>R 11 E</u>	
X Distance and direction from nearest town or city: <u>2 mi. NW of Madison</u>	
3. Owner of well: <u>Mary Headrick</u> R.R. or street: <u>1418 Neosho</u> City, state, zip code: <u>Emporia, KS, 66801</u>	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. <u>6</u> in. Completion date <u>5-21-79</u> Well depth <u>70</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
X Casing: Material <u>PL</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>32</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.5</u> lbs./ft. Dia. <u>5</u> in. to <u>70</u> ft. depth Wall Thickness: inches or Dia. <u>1/2</u> in. to <u>70</u> ft. depth Gauge No. <u>200</u>	
10. Screen: Manufacturer's name <u>Sunflower</u> <u>Sub set well casing</u> Type <u>RMP</u> Dia. <u>5</u> " Slot/gauze <u>.06</u> Length <u>46</u> ' Set between <u>17</u> ft. and <u>57</u> ft. <u>64</u> ft. and <u>70</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>4-1/2"</u>	
11. Static water level: <u>17</u> ft. below land surface Date <u>5-21-79</u> mo./day/yr.	
12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>3/4</u> g.p.m.	
13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
14. Well head completion: <u>32</u> inches above grade ____ Pitless adapter	
15. Well grouted? ____ With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
16. Nearest source of possible contamination: <u>2000</u> ft. Direction <u>NW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope ____ Upland ____ Valley	
19. Remarks: <u>The well is located in a meadow.</u> <u>A submersible pump will be in-</u> <u>stalled by a plumber.</u> <u>The owner is installing 4'x6' curb.</u>	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Lespagnard W.W. Contrs, 372</u> Business name <u>1312 Trail Ridge Rd</u> License No. <u>1312</u> Address <u>George J. Lespagnard</u> Date <u>5-24-79</u> Signed <u>George J. Lespagnard</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5