

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

FROM WATSON - 2 1/2 E - 13/4 S

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County HARVEY Fraction NW 1/4 SW 1/4 SW 1/4 Section number 34 Township number 22-5 S Range number R2-E E/W	
2. Distance and direction from nearest town or city: 3/4 MILES SOUTH 3. Owner of well: GAYLORD CONNOR R.R. or street: RR #4	
Street address of well location if in city: 2 1/2 MILE EAST City, state, zip code: Newton Kansas 67114	
4. Locate with "X" in section below: 	6. Bore hole dia. 8.0 in. Completion date 9/7/78 Well depth 71 ft.
	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
	9. Casing: Material Plast. Pipe Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. RMP *** PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 51 ft. depth Wall Thickness inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 200
5. Type and color of material	10. Screen: Manufacturer's name Sunflower Plast. Pipe Type 200 Dia. 5" Slot/gauze slot 1/16" Length 20' Set between 51 ft. and 71 ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4 - 1/2"
Top soil	From 0 To 3
Limestone rock	From 3 To 14
Light colored shale	From 14 To 21
Dark blue shale	From 21 To 69-71
	11. Static water level: <input type="checkbox"/> mo./day/yr. 19 ft. below land surface Date 9/7/78
	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
	13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____
	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 30" Inches above grade
	15. Well grouted? yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.
	16. Nearest source of possible contamination: ft. 105' Direction se Type Lagon Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
	17. Pump: Not installed Manufacturer's name Goulds Model number 10E109412 HP 1/2 Volts 230 Length of drop pipe 65 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN SUPPLY 362 Business name License No. Address 500 W22ND NORTH NEWTON Signed Burt Adams Date 9/7/78 Authorized representative
19. Remarks:	

22-2034 NW SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5